



Request for Information

RFI No.: 5
Change Issue: _____
Date: 01/29/09

Project: GC & SU Campus Theatre Develop
Job No.: 206344-
Owner: USG Real Estate Foundation
A/E: Dunwody / Beeland, Architects, Inc.
A/E Project No: _____

To: Dunwody / Beeland, Architects, Inc.
300 Mulberry St., Ste. 604
Macon, GA 31202

From: Garbutt-Christman
Matt Brownell

Attn: Robbie Beeland
Cc: _____

Reference Documents: _____
Submittal: _____ Spec. Section: _____
Drawing No.: SI.2A Schedule No.: _____
Addendum: _____

Subject: Steel angle size change

Information Requested:

Section SI.2-A @ new columns calls for L5"x5"x7/8"x1'-1". ISM is having trouble locating this material size. Please confirm it is acceptable to substitute this size with an L5"x5"x3/4".

Thank You

Required resolution date to avoid delay: 02/05/09 Originator's Signature: _____
Matt Brownell

Response:

L5" x 5" x 3/4" is acceptable
1/29/09

Approved by: Firm: *D/B* Signature: *[Signature]*

Copy : Dunwody / Beeland, Architects, Inc. USG Real Estate Foundation WC's _____