

Garbutt Christman

621 Academy Avenue

Dublin, GA 31021

REQUEST FOR INFORMATION

No. 00015

Phone: 478-272-4410

Fax: 478-275-0642

TITLE: Water Piping

DATE: 8/20/2009

PROJECT: Hendricks Hall

JOB: 08047

TO: Attn: Gary A Mueller

Cogdell Mendrala Architects

517 East Congress Street

Savannah, GA 31401

Phone: 912-234-6318

STARTED:

COMPLETED:

REQUIRED: 8/27/2009

QUESTION:

Specification Section 220310-2.01-1-4 references CPVC pipe for domestic water piping while section 221110-2.01-C calls for Type L copper. Please advise if CPVC pipe and fittings will be acceptable for the domestic water piping system.

ANSWER:

RESPONSE FROM PLUMBING CONSULTANT:

Specification Section 220310 defines the standards each piping material must adhere too. Section 221110 lists the actual material required for the water system, just as 221210 lists the required piping materials for the soil, waste and vent systems. CPVC is not acceptable for this project.

Answered By: Cogdell & Mendrala

Signed:



Date:

8/20/09