



REQUEST FOR INFORMATION
No. 00038

TITLE: Back Porch Decking

DATE: 4/15/2009

PROJECT: Renovate/Stabilize Huntington Hall

JOB: 1315

TO: Attn: Joseph Robinson , Jr.
J W Robinson & Associates

STARTED:

COMPLETED:

REQUIRED: 4/22/2009

REQUEST:

The drawings call for 1x4 T & G floor decking on the rear porch. Our concern is that the decking will buckle, seeing that the boards can only be nailed in the tongue every 16". Per your conversation with Rayford Tuesday, 04/14/09, it was agreed upon to use treated 1x6 for the back porch floor decking and face nail the boards. Please confirm that this is acceptable.

ANSWER:

Requested By: Garbutt Construction Company

Date: 4/15/2009

Signed: _____
Adam McEachern