

Garbutt Construction Company

P.O. Box 712
621 Academy Ave
Dublin, GA 31040

Phone: 478-272-4410
Fax: 478-275-0642

REQUEST FOR INFORMATION

No. 00005

TITLE: Rebuilding Back Porch

DATE: 11/3/2008

PROJECT: Renovate/Stabilize Huntington Hall

JOB: 1315

TO: Attn: Stanley Jennings
J W Robinson & Associates
1020 Ralph David Abernathy Blvd, SW
Atlanta, GA 30310
Phone: 404-753-4129 Fax: 404-753-4435

STARTED:
COMPLETED:
REQUIRED: 11/10/2008

WORK
IMPACT: No

SCHEDULE
IMPACT: No

COST
IMPACT: No

REQUEST:

Detail 5 / A-1.7 refers to re-using the existing concrete porch slab and wrought iron supports for the back porch. As directed at the site and as referenced in RFI # 2 the back porch has been completely removed. All existing materials that were salvageable were saved and are currently stored at the site. Please provide direction and

PROPOSED SOLUTION:

ANSWER:

Yes this is to confirm that the existing rear porch because of the difficulty it caused for the waterproofing and because of its construction and condition.

A drawing detailing the replacement is currently being worked on.

Because the rear entry must also include a ramp (future construction) we are attempting to make provisions for it now within the design. This effort requires more than a days time to complete. The revised drawing showing the replacement porch details will be provided as soon as possible.

Requested By: Garbutt Construction Company

Date: 11/3/2008

Signed: _____
Sean Moxley