



REQUEST FOR INFORMATION

No. 00007

P.O. Box 712
621 Academy Ave
Dublin, GA 31040

Phone: 478-272-4410
Fax: 478-275-0642

TITLE: Door Frames and Hardware
PROJECT: Renovate/Stabilize Huntington Hall
TO: Attn: Stanley Jennings
J W Robinson & Associates
1020 Ralph David Abernathy Blvd, SW
Atlanta, GA 30310
Phone: 404-753-4129 Fax: 404-753-4435

DATE: 11/3/2008
JOB: 1315
STARTED:
COMPLETED:
REQUIRED: 11/10/2008

REQUEST:

The Door Schedule on sheet A1.6 of the drawings calls for hollow metal frames for doors B02,101,102,103. Details 5, 6, & 7 on sheet A1.6 depict wood door frames. Please advise if these door will require wood or hollow metal door frames, please provide a specification for whichever is required.

Also, There is no reference to door hardware in the plans or specifications, please provide direction on this.

ANSWER:

The details within the documents are correct. The doors will have wood frames. Vintage style door hardware will be provided shortly.

Requested By: Garbutt Construction Company

Date: 11/3/2008

Signed: _____
Sean Moxley