



REQUEST FOR INFORMATION
No. 00076

TITLE: Revision 19 HM Frame Questions
PROJECT: New College Renovation
TO: Attn: LISA KEHOE
Wilson and Dawson Architects

DATE: 1/12/2010

JOB: 1317

STARTED:

COMPLETED:

REQUIRED: 1/19/2010

REQUEST:

1. Please provide detail for opening into office 319 on sheet A-104. Is this to be a cased opening or sheetrock opening? If this is to be a sheet rock opening, is a corner guard required?
2. Please provide elevation of door / HM Frame 321A. What wall type is this frame to be placed in? Is the transom wood or glass? Please clarify.

ANSWER:

1. Opening at 319 will be a sheet rock opening. No corner guards are required.
2. Door 321 will be a wood/glass door type G5/G003, Frame type E5/G003 with no transom above. See architectural drawings J1/G601 OH for configuration.

Requested By: Garbutt Construction Company

Date: _____

Signed: _____
Adam McEachern