



REQUEST FOR INFORMATION
No. 00111

TITLE: Control Valve Location	DATE: 4/8/2010
PROJECT: New College Renovation	JOB: 1317
TO: Attn: Jim Wilson Wilson and Dawson Architects 417 Edgewood Avenue Atlanta, GA 30312 Phone: 404-815-0607 Fax: 404-815-0609	STARTED: COMPLETED: REQUIRED: 4/15/2010

REQUEST:

Due to accessibility constraints in the N. stairwell, would it be permissible to place all control valves and isolation valves to fan power boxes in the basement?

ANSWER:

Answer per Morley Spencer of Spencer Bristol Engineering:

We approve locating the control valves in the basement provided that they are properly tagged as to their function and also that a placard be placed in or on the fan power boxes (fan coil units?) indicating where the control valves may be found.

Requested By: Garbutt Construction Company

Date: _____

Signed: _____
Adam McEachern