

# Garbutt Construction Company

REQUEST FOR INFORMATION

No. 00048

**TITLE:** Window Changes

**DATE:** 11/2/2009

**PROJECT:** New College Renovation

**JOB:** 1317

**TO:** Attn: Jim Wilson  
Wilson and Dawson Architects  
417 Edgewood Avenue  
Atlanta, GA 30312  
Phone: 404-815-0607 Fax: 404-815-0609

**STARTED:**

**COMPLETED:**

**REQUIRED:** 11/9/2009

**REQUEST:**

Per our discussion at the jobsite meeting 10/29/09, the following changes have been made to the window package:

1. The exterior brick mould will be furnished in cypress in lieu of mahogany. It will not be furnished by the window manufacturer, but by the window installer.
2. The window sill nosing will be changed from a standard sill nosing to a 2" sill nosing. This will allow us to use a standard window size in lieu of a custom size. Please see attached drawing from Kolbe.

Please confirm this is acceptable.

**Requested By:** Garbutt Construction Company

**Signed:** 

Adam McEachern

**Date:** 11/2/09

Expedition ©

**ANSWER:**

1. It is acceptable to use cypress instead of mahogany for the exterior brick mould. This will be provided by window installer who will be a separate entity from window manufacturer.
2. Use 2" sill nosing instead of standard sill nosing to allow use of standary window size.

**Answered By:** Wilson and Dawson Architects

**Date:** 11/03/09

**Signed:** \_\_\_\_\_

Jim Wilson