

Garbutt Construction Company

REQUEST FOR INFORMATION

No. 00037

TITLE: Chilled Water Meter

DATE: 10/7/2009

PROJECT: New College Renovation

JOB: 1317

TO: Attn: Jim Wilson
Wilson and Dawson Architects
417 Edgewood Avenue
Atlanta, GA 30312
Phone: 404-815-0607 Fax: 404-815-0609

STARTED:

COMPLETED:

REQUIRED: 10/14/2009

REQUEST:

Newton Clark of Mock Mechanical asked the question: Is a chilled water meter required? If so, please advise what the specification is.

Requested By: Garbutt Construction Company

Date: 10/7/09

Signed: 
Adam McEachern

Expedition ©

ANSWER:

Answer per Morley Spencer, Spencer Bristol:

Please refer to most current mechanical drawings last revised with Addendum 04 , with label "Addendum 04, 05.22.009" in the title block.

From this latest set of drawings, please refer to sheet M-002, detail 3/M002, Chilled Water Schematic. This detail references a chilled water meter, connected to the BAS. Please coordinate with UGA-PPD, HVAC division, as to their exact preference for the style and manufacturer of this meter.

Answered By: Wilson and Dawson Architects

Date: 10/09/09

Signed: _____
Jim Wilson